



6. Where not all accessible spaces have the 98 inch minimum clearance, van accessible spaces shall provide a sign indicating “van accessible”.      Yes      No      **N/A**

**Notes** \_\_\_\_\_

7. All accessible parking spaces shall have an adjacent access aisle measuring a minimum of 8 feet in width. Two parking spaces can share the same access aisle.      Yes      **No**

**Notes**      **No aisle is available for accessible parking spaces** \_\_\_\_\_

8. Van accessible parking spaces that are angles shall have the access aisle located on the passenger side of the parking space.      Yes      No      **N/A**

**Notes** \_\_\_\_\_

9. Each access aisle shall be provided with a sign indicating “No Parking”.      Yes      No  
**N/A**

**Notes** \_\_\_\_\_

10. Access aisle signs shall be centered at the head end of the access aisle and mounted between 60 and 66 inches above the surface of the access aisle measured to the bottom of the sign.      Yes      No      **N/A**

**Notes** \_\_\_\_\_

11. Where the access aisle sign would obstruct a curb ramp or pedestrian route, the no parking designation shall be provided on the surface of the access aisle.      Yes      No  
**N/A**

**Notes** \_\_\_\_\_

12. Where the parking space and access aisle are located in an enclosed structure or otherwise protected from the elements, the no parking designation shall be permitted to be provided on the surface of the access aisle.      Yes      No      **N/A**

**Notes** \_\_\_\_\_

13. The slope of each accessible parking space and access aisle shall not exceed 1:48.  
Yes      **No**

**Notes**      **Slope for parking spaces are 4.6%** \_\_\_\_\_

14. Each access aisle shall connect to an accessible route.      Yes      No      **N/A**

**Notes** \_\_\_\_\_

15. Accessible spaces shall be located as near as possible to an accessible building entrance.  
Yes      No      **N/A**

**Notes** \_\_\_\_\_